



NOTES:

1. SIZE PRV-1 FOR 1/3 OF THE TOTAL BUILDING STEAM LOAD AND SIZE PRV-2 FOR 2/3 OF THE TOTAL BUILDING STEAM LOAD.
2. ALL VALVES AND FITTINGS OF THE PRESSURE REDUCING STATION SHALL BE INSULATED.
3. USE SCHEDULE 80 PIPE FOR ALL HORIZONTAL PIPING.
4. INSTALL AT SUFFICIENT HEIGHT TO ALLOW ALL CONDENSATE FROM TRAPS TO DRAIN BY GRAVITY.
5. MAINTAIN MOUNTING HEIGHT LOW ENOUGH FOR MAINTENANCE SERVICE WITHOUT USE OF LADDER.
6. ALL COMPONENTS (TRAPS, VALVE, ETC.) MUST HAVE UNIONS OR FLANGES.
7. REFER TO PLANS FOR PIPE SIZES.
8. LOW PRESSURE CONDENSATE DRAIN LINE SHALL BE SLOPED TO CONDENSATE RECEIVER.
9. HIGH PRESSURE CONDENSATE SHALL BE PIPED TO FLASH TANK.

